

## EMC shield for IQ8Quad, ES Detect detector base

---



### Part-No. 805560

In fire alarm systems where a high electromagnetic interference/EMI load (e.g. by fluorescent lamps or electrical control devices) must be expected it is recommended to mount the EMI-Module in the standard detector base (Part No. 805590) of the corresponding fire alarm detectors.

Air humidity	< 95 %
--------------	--------



The EMI-Module must only be operated in conjunction with standard IQ8Quad detector base (without relay board) and only for detectors without integrated alarm devices (Part No. 802382 to 802386, incl. adapted variants).